


12kV Outgoing Metal-Clad Switchgear
12kV Çıkış Hücresi



12kV	630-1250A	2000-2500A	2500-3150A
W	700	850	1100

(D) CABLE COMPARTMENT
KABLO BÖLMESİ

(A) LOW VOLTAGE COMPARTMENT
ALÇAK GERİLİM BÖLMESİ

(B) CIRCUIT BREAKER COMPARTMENT
KESİCİ BÖLMESİ

(C) BUS-BAR COMPARTMENT
BARA BÖLMESİ